

Link Vent 2000

2000 VENT (using a 2500 vent with a 10 mm rout height)

Equivalent Area Free Area Acoustic D n,e,w (+/-) - vent open Acoustic D n,e,w (+/-) - vent closed
 2000mm² EQA 2019mm² 35 (-1;1) 40 (-1;-2)

Draft acoustic data, to be finalised.

Internal				External								Ventilator			
Ventilator				Canopy				Grille (Timber, Sliding door, Sash)							
H (mm)	L (mm)	D (mm)	Weight (gram)	H (mm)	L (mm)	D (mm)	Weight (gram)	H (mm)	L (mm)	D (mm)	Weight (gram)	Attachment type	Rout H (mm)	Rout L (mm)	Stand W (mm)
18.5	236.5	15	30	18.5	236.5	25	30	26	236.5	2.5	11	Clip or Screw	10	204	na

EQUIVALENT AREA – 2500 vent (2000EQA)

AIR LEAKAGE – 2500 vent 0.39 m³/h 0.11 L/s

WATERTIGHTNESS TEST TO BS EN 13141-1 – 2500 vent – Resistant to water penetration using method 1A meeting Class 9A requirement up to and at 900pa in BS EN 12208

DB RATING – Airbourne sound insulation to BS EN ISO 10140-1:2016 Annex E and BS EN ISO 10140-2:2010 and single number calculated in accordance with BS EN ISO 717-1:2013

Link Vent 2500

2500 VENT

Equivalent Area 2500mm² EQA Free Area 2518mm² Acoustic D n,e,w (+/-) - vent open 34 (-1:1) Acoustic D n,e,w (+/-) - vent closed 46 (-1;-1)

Internal				External								Ventilator			
Ventilator				Canopy				Grille (Timber, Sliding door, Sash)				Ventilator			
H (mm)	L (mm)	D (mm)	Weight (gram)	H (mm)	L (mm)	D (mm)	Weight (gram)	H (mm)	L (mm)	D (mm)	Weight (gram)	Attachment type	Rout H (mm)	Rout L (mm)	Stand W (mm)
18.5	236.5	15	30	18.5	236.5	25	30	26	236.5	2.5	11	Clip or Screw	13	204	na

EQUIVALENT AREA – 2500 vent (2500EQA)

AIR LEAKAGE – 2500 vent 0.39 m³/h 0.11 L/s

WATERTIGHTNESS TEST TO BS EN 13141-1 – 2500 vent – Resistant to water penetration using method 1A meeting Class 9A requirement up to and at 600pa in BS EN 12208

DB RATING – Airbourne sound insulation to BS EN ISO 10140-1:2016 Annex E and BS EN ISO 10140-2:2010 and single number calculated in accordance with BS EN ISO 717-1:2013